

DESIGN CALCULATION

PROJECT TITLE

PROVIDING DRINKING WATER TO HABITATIONS
IN KOMARAMBHEEM ASIFABAD SEGMENT
IN ADILABAD DISTRICT (30 MLD WTP)

UNIT

90 KL GLBR AT MADHARAM GUTTA

DCI NO: - LE150883-C-WS-RW-DC-1590

PRINCIPAL CLIENT

RURAL WATER SUPPLY
AND
SANITATION DEPARTMENT,
TELANGANA

CONTRACTOR

L&T CONSTRUCTION
WATER & EFFLUENT TREATMENT SBG

DESIGN OF GLBR

BASIC DATA

Diameter = 6.0 m
Water depth = 3.25 m
Free board = 0.3 m

CAPACITY CHECK

Required capacity = 90 KL

Capacity of section

Clear diameter = $6.0 - 2 \times 0.012$
= 5.976 m

Water depth = 3.4 m

Volume = $(\pi \times d \times d / 4) \times H$
= $(\pi \times 5.976 \times 5.976 / 4) \times 3.4 = 95.36 \text{ m}^3$ (including dead storage)

Volume-Dead storage = $95.36 - 4.20 = 91.16 \text{ m}^3$

Net volume = $91.16 \text{ m}^3 > 90 \text{ m}^3$ hence O.K.

ELEMENT:

Inside tank: (1) Cylindrical wall
(2) Top Slab

SBC = 15 t/m^2

GROUND WATER TABLE: NO GW

Tank type : Ground storage reservoir			
Tank Geometry : Circular with slab			
90 KL GLBR			
Basic data			
General			
No	Description	Notation	Value
(A)			
	Unit weight of concrete	Uwc	25.0 kN/m ³
	Unit weight of water	Uww	10.00 kN/m ³
	Unit weight of plaster	Uwp	21.0 kN/m ³
	Unit weight of PS	Uips	21.0 kN/m ³
	Unit weight of soil	Uws	18.0 kN/m ³
(B)			
	Grade of concrete of container	Fck	30 N/mm ²
	Grade of Steel	Fy	500 N/mm ²
	Mass & Wt relation factor	g	9.81
(C)			
	Loading		
	Finishing load on top slab	Fi	1.00 kN/m ²
	Live load on top slab	Li	1.50 kN/m ²
	Other		
(D)			
	Plaster thickness	Pt	20 mm
	Bottom IPS thickness	Bips	20 mm
	Free board	Fb	300 mm
(E)			
	Capacity		
	Required volumn of water	Vw	90 m ³
	Geometry data	Vwl	90000 liter
(F)			
	Height between Bottom slab & FSI	Hw	3.4 m
	Depth below ground	Dbgl	0.5 m
	Water depth	Wd	3.4 m
	Diameter of tank required	Diar *	5.85 m
	Diameter of tank provide	Diat	6 m
	Actual capacity of tank	Tcap	94.855 m ³
	RCC geometry data	Tcapl	94855 liter
(G)			
	Bottom slab thickness	Thkbs	200 mm
	Top Slab thickness	Thkts	200 mm
	Wall thickness	Thkw	175 mm
	Projection of bottom slab	Pjbs	300 mm
	Projection of PCC	Pjpsc	100 mm
	Thickness of PCC	Thkpsc	100 mm
(H)			
	Earthquake data		
	Zone	Egzone	2
	Soil type (1,2,3)	typesoil	2
	soft soil : Soil type 1		
	Medium soil : Soil type 2		
	Hard soil : soil type 3		
	Importance Factor	Impfac	1.5

Tank Geometry : Circular with slab			
90 KL GLBR			
Mass & Weight Calculation			
RCC			
(A)	Bottom slab		
	Out to out dia of bottom slab	Bso	6.95
	Thickness of bottom slab in m	thkbsm	0.20
	Volume of bottom slab	Vbs	7.59
	Weight of bottom slab	wbs	189.68
	Mass of bottom slab	Mbs	19336
(B)	Side wall		
	C/C wall dia	Wdiacc	6.18
	Total height of wall	Wht	3.70
	Thickness of wall in meter	thkwm	0.18
	Volume of side wall	Vw	12.56
	Weight of side wall	Ww	314.03
	Mass of side	Mw	32011
(C)	Top slab		
	Out to out dia of top slab	Tso	6.35
	Thickness of top slab in m	thktsm	0.200
	Surface area of top slab		31.67
	Volume of top slab	VTs	6.33
	Weight of top slab	wts	158.35
	Mass of top slab	Mts	16141
(D)	bottom IPS		
	Area of Bottom IPS	Arips	28.27
	Weight of bottom IPS	Wrips	11.88
	Mass of bottom IPS	Mrips	1211
(E)	Plaster		
	Area of Plaster on wall	Arpsw	69.74
	Weight of plaster on wall	Wpsw	29.29
	Mass of plaster on wall	Mpsw	2986
	Area of Plaster top slab	Arpsts	28.27
	Weight of plaster on top slab	Wpsts	11.88
	Mass of plaster on top slab	Mpsts	1211
(F)	Finishing load		
	Area of Finishing load	Arfl	31.66922
	Weight of finishing load	Wfl	31.66922
	Mass of finishing load	Mfl	3228.259
(H)	Water		
	Weight of water up to FSL	Wwfsi	948.55
	Mass of water upto FSL	Mwfsi	96692
	Weight of water in free board	Wwfb	83.70
	Mass of water in free board	Mwfb	8532
	Total weight of water	Tww	1032.25
	Total mass of water	Tmw	105224
	Total mass		181347
	Total wt		1779

Tank Geometry : Circular with slab			
90 KL GLBR			
Parameter of spring mass Model			
(A)	H/D calculation		
	Height of tank including Freeboard	H	3.7 m
	Inside Diameter of tank	D	6 m
	H/D ratio - Ra	Ra	0.617
	D/H ratio Rb	Rb	1.62
(B)	Mass calculation		
	Total mass of water	M	105224 kg
	Calculation of Impulsive mass		
	$m_i/m = \tanh(0.866d/h)$		
	0.866 d/h		
	Mi/m - Ratio Rd	Rd	0.6311
	Calculation of Convective mass		
	$m_c/m = 0.23 * \tanh(3.68h/d)$		
	h/d		
	Mc/m - Ratio Re	Re	0.365
		Mc	38416 kg
	Total mass of water	Tm	104824
(C)	Calculation of Height Hi & Hc		
	for hydrodynamic pressure on tank wall only		
	For H/D < 0.75 , hi = 0.375		
	For H/D > 0.75		
	hi/h = 0.5 - 0.09375/(h/d) - Ratio Rf	Rf	0.375
	hia	hia	1.388 m
	hc/h = 1-cosh(3.68 h/d)-1	Rg	0.642
	3.68 h/d sinh(3.68 h/d)	Hca	2.375 m
(D)	Calculation of Height Hi* & Hc*		
	Hi for hydrodynamic pressure on tank wall and base slab		
	For H/D < 1.33		
	$h_i^*/h = \frac{2 \tanh(0.866d/h)}{0.866d/h} * - 0.125$		
	For H/D > 1.33		
	hi*/h = 0.45	Rh	0.667 m
		hib	2.469 m
	hc*/h = 1-cosh(3.68 h/d)-2.01	Ri	0.735
	3.68 h/d sinh(3.68 h/d)	Hcb	2.719 m
(E)	Calculation of spring stiffness		
	$k_c = 0.836 * mg/h * \tanh^2(3.68 h/d)$	Kc	223471

Tank Geometry : Circular with slab			
90 KL GLBR			
Time Period			
(A)	CI		
		Coefficient for Calculation of	
		Time period in Impulsive mode time	
	CI =	1	
		$(h/d)^{0.5} * (0.46 - 0.3 * h/d + 0.067 * (h/d)^2)$	
	CI	4.238	
(B)	Cc		
		Coefficient for Calculation of	
		Time period in Convective mode time	
	Cc =	$\frac{2 * \pi I}{3.68 * \tanh(3.68h/d)^{0.5}}$	
	Cc	3.311	
(C)			
		Time period in Impulsive mode	
		$TI = CI * H * (mdwt)^{0.5} / (Iw/D)^{0.5} (E)^{0.5}$	
		mass density of water	
	mdwt	1019.368	kg/m ³
	TI	0.018	second
(D)			
		Time period in Convective mode	
		$Tc = Cc * (D/g)^{0.5}$	
	Tc	2.589	second

Tank Geometry : Circular with slab		
90 KL GLBR		
Horizontal seismic coefficient		
(A)	Zone factor Z	
	Earthquake zone	2
	Zone Factor : Z	0.1
	Importance factor	1.5
	Soil type	st
(B)	Response reduction factor	
	Response reduction factor for ground supported tank	2
	Response reduction factor for under ground tank	4
	Response factor for partial under ground tank above ground	1.30
	Tank above ground	1.30
	Tank below ground	0.50
	Total height of tank	3.70
	Ratio for partial buried	0.135
	Partial R	2.270
(C)	Calculation for Sa/g : for impulsive mode	
	Time Period T _I	0.0177
	Sa/g : For Soft soil	2.5
	Sa/g : For Medium soil	2.5
	Sa/g : For hard soil	2.5
	Seismic coefficient for impulsive mode	sag
(D)	Seismic coefficient for impulsive mode	
	Ah _i = Z / 2 * I / R * Sa/g	Ah _i
	Calculation for Sa/g : for convective	0.082589
(E)	Calculation for Sa/g : for convective	
	Time Period T _c	2.59
	Sa/g : For Soft soil	0.645
	Sa/g : For Medium soil	0.525
	Sa/g : For hard soil	0.386
	Sag for 0.5 % damping = sag * 1.75	sag ₁
	Seismic coefficient for impulsive mode	0.92
(F)	Seismic coefficient for impulsive mode	
	Ah _c = Z / 2 * I / R * Sa/g	Ah _c
	Calculation of base shear due to impulsive mode	0.030
(G)	Calculation of base shear due to impulsive mode	
	VI = Ah _i * (Mass of tank + Mass of water in impulsive mode) x G	
	VI	98.83
(H)	Calculation of base shear due to convective mode	
	V _c = Ah _c * (Mass of water in convective mode) x G	

Tank Geomtry : Circular with slab			
90 KL GLBR			
Horizontal seismic coefficient			
	Vc	11.44	KN
(i)	Total base shear		
	$V = (V_l^2 + V_c^2)^{0.5}$	V	99
(j)	Moment at bottom of wall		
	Impulsive mode		
	Mombt : $Ah_i^*(m_i^*h_i + Mw^*hw + Mt^*ht) * G$		kn-m
	Impulsive mass of water	66408	1.39
	92141		
	Mass of wall	32011	1.85
	59220		
	Mass of plaster	2986	1.85
	5524		
	Mass of top slab	16141	3.80
	61337		
	Mass of topslab finishing	3228	3.90
	12590		
	230812		
	Moment = $Afi * (Sigma M * H) * G$	mombt	187.0
	Center of gravity of slab		
	=slab thickness / 2		0.100
(k)	Moment at bottom of wall		
	Convective mode		
	Mombt : $Ahc^*(mc^*hc) * G$	mombtc	27.18
	27.18		kn-m
(L)	Total bending moment		
	mombt		
	$= ((mombt^2 + mombtc^2)^{0.5})$	Momto	188.97
			kn-m

Tank Geometry : Circular with slab			
90 KL GLBR			
Horizontal seismic coefficient			
(M)	Over turning moment		
	Impulsive mode		
	$ah_i(m_i(h_i+thkbs)+mw(hw+thkbs)+mt(hw+thkbs+thkbs/2)+mb*thkbs/2)$		
	Item	mass	distance
	Impulsive mass of water	66408	2.67
	Mass of wall	32011	2.05
	Mass of plaster	2986	2.05
	Mass of top slab	16141	4.00
	Mass of topslab finishing	3228	4.10
	Mass of bottom slab	19336	0.10
	Mass of Bottom Ips	1211	0.20
			328952.67
	Moment = $Af_i * (\text{Sigma } M * H) * G$	momovei	266.52
(N)	Over turning moment		
	Convective mode		
	moment = $Ahc*Mc*(hc+thkbs)G$	momovec	33.41
	Total Moment of overturning	Momovto	268.60
	P/A	preaa	46.89
	M/z	Prebb	8.15
	P/a+m/z	Pmax	55.04
	P/a-m/z	Pmin	38.74
	Slushing Wave Height		
(P)	Wavh = $Ahc * R * D/2$	Wavh	0.207
(Q)	Anchore Requirement		
	h/d ratio	0.6167	
	1/ahi	12.1081	
	h/d > 1/ahi		No anchorage required

Tank Geometry : Circular with slab		90 KL GLBR		Hydrodynamic Pressure	
A	Impulsive hydrodynamic pressure at base of wall	Piw			
B	Impulsive hydrodynamic pressure at base slab	Pib			
C	Convective hydrodynamic pressure at base of wall	Pcw			
D	Impulsive hydrodynamic pressure at base of wall	Pcb			
E	Pressure due to wall inertia	Pw			
F	Pressure due vertical excitation	Pv			
A Impulsive hydrodynamic pressure at base of wall					
Pressure on wall due to impulsive load					
$Pw = Qiw * (y) * ahi * ro * G * h * Cos phi$					
for maximum value angle phi = 0, cos phi = 1					
$Qiw = 0.866 * (1-(y/h)^2 * tanh(0.866D/h))$					
Table					
Diameter of Tank = 6.00 m					
Total Height of tank = 3.70 m					
D/h ratio = 1.62					
$tanh(0.866D/h) = (A)$					
$Ahi * ro * G * h * Cos phi = (C)$					
No	y/h	Y	$(1-(y/h)^2) * 0.866 * A * B$	Piw	kn/m ²
1	0	0.00	1	0.768	2.3
2	0.1	0.37	0.99	0.760	2.3
3	0.2	0.74	0.96	0.737	2.2
4	0.3	1.11	0.91	0.698	2.1
5	0.4	1.48	0.84	0.645	1.9
6	0.5	1.85	0.75	0.576	1.7
7	0.6	2.22	0.64	0.491	1.5
8	0.7	2.59	0.51	0.391	1.2
9	0.8	2.96	0.36	0.276	0.8
10	0.9	3.33	0.19	0.146	0.4
11	1	3.70	0	0.000	0.0
Pressure on wall due to impulsive load at Y = 0					
2.3					

Tank Geometry : Circular with slab		90 KL GLBR		Hydrodynamic Pressure	
D		Convective hydrodynamic pressure at base of slab			
Pressure on slab due to convective mode					
ahc		0.0303684			
Pcb = Qcb*ahc*ro* g * D		1787			
Qcb = 1.125(x/D-4/3(x/d) ³ sech(3.674h/d))					
x = d / 2		3.70			
h		6.00			
d		3			
x		0.5			
x/d		4.8704953			
cosh(3.675h/d)		0.2053179			
sech(3.674 h/d)		0.0769942			
qcb		0.1376259			
Pcb		0.138			
Final summary					
1		Impulsive hydrodynamic pressure at base of wall		2.301 kn/m ²	
2		Impulsive hydrodynamic pressure at base slab		3.953 kn/m ²	
3		Convective hydrodynamic pressure at base of wall		0.138 kn/m ²	
4		Impulsive hydrodynamic pressure at base of wall		0.138 kn/m ²	
E		Pressure due to wall inertia			
P _w = ah _i ³ *r _o ³ * G					
Ah _i		0.0825893			
hor. Seismic coef. In impls					
wall thickness		0.175 m			
rom*G		mass density* G			
25		kn/m ³			
P _w		0.361328 kn/m ²			

Tank Geometry : Circular with slab	
90 KL GLBR	
Hydrodynamic Pressure	
F	Pressure due vertical excitation
	$P_v = a_v * (r_o * g * h * (1-y/h))$
	$a_v = 2/3 * (Z/2 * I/R * S_a/g)$
Z	zone factor
I	Importance factor
R	response factor
Sa/g	acceleration
	0.1
	1.5
	2.270
	2.5
	Av
	0.055
	for y = 0 at base level
	$r_o * g * h * (1-y/h)$
	36.297
	Pv
	1.998496 kn/m2
F	Maximum hydrodynamic pressure
	$P_{max} = ((P_{iw} + P_{ww})^2 + P_{cw}^2 + p_v^2)^{0.5}$
	Pmax
	3.332 kn/m2
	Pmax is about
	9.0045093 %
	< 33.33 %
	Maximum hydrodynamic froce in normal condition
	37.00 kn/m2
	As hydrodynamic force < 33 % it will not govern in design

SUMP : 90 KL		FORMULA	
PROJECT: PROVIDING DRINKING WATER TO HABITATIONS IN KOMARAMBHEEM ASIFABAD SEGMENT IN ADILABAD DISTRICT (30 MLD WTP)		GLBR AT	CLIENT
STRUCTURE		Madharan Gutta	RURAL WATER SUPPLY AND SANITATION DEPARTMENT, TELANGANA
DESIGN CALCULATION FOR GLBR		DATE	REV
		23/03/2016	0
DESIGN CALCULATION DATA			
General Data		Sumpcap	90.000 m ³
Required Capacity of Sump			
Location			
Hydraulic Features		GL	0.00 m
Ground Level		Ds	0.15 m
Dead Storage		FB	0.30 m
Free Board			
Basic Shape :		Circular with flat slab	
unit weight of concrete		Material Data	
unit weight of water		UWC	25.000 KN/m ³
unit weight of plaster		UWW	10.000 KN/m ³
		UWP	21.000 KN/m ³
live load at roof slab		load Data	
Finish load		lff	1.500 KN/m ²
		Fl	1.000 KN/m ²
Geometry Data			
Diameter	Dia	6.00	m
Depth of tank above GL		3.20	
Depth of tank below GL		0.50	
Water depth : With Dead storage	Wd	3.40	m
Top Slab thickness	Tsthk	0.200	m
		As per tender Specification	

Bottom slab thickness	Bsthk	0.200	m	
plaster thickness	pt	0.012	m	
Permissible stress (As per IS 456 & IS 3370)				
Concrete				
Concrete grade -FCK	fck	30	N/mm ²	
per. stress in con. for direct comp	fcck	8.0	N/mm ²	
per. stress in con in com. due to bending	fcckbc	10.0	N/mm ²	
per. stress in con. for direct tension	fcct	1.5	N/mm ²	
per. stress in con. In ten due to bending	fcctb	2.0	N/mm ²	
modulus of elasticity for container	em	2.74E+04	N/mm ²	=5000*(fck) ^{0.5+100}
Reinforcement	fy	500	N/mm ²	
per. Ten. str.- steel tension due to bending	fyc	130	N/mm ²	
per. Ten. str.- steel tension due to direct ten	fyuc	130	N/mm ²	
Modular ratio	md	9.33		
Dimension for minimum steel	Dmin	15.0	m	
Mass & Wt relation factor	g	9.810		
[A] CAPACITY OF CONTAINER				
Volume Calculation				
Water Depth with Dead Storage	Wdd	3.400		
Inside Diameter		6.000		
Clear Inside Diameter without plaster	Diac	5.976		
total volume	vt	95.37	m ³	
dead storage	vdd	4.21	m ³	
net volume	vn	91.16	m ³ >	90.000 OK
[B] TOP SLAB DESIGN				
Concrete grade	Fck	30	N/mm ²	
Steel	Fy	500	N/mm ²	
Clear cover	Cv	45	mm	
Slab Diameter	Lx	6.000	m	
Slab type	St	1	Simply supported	

Width	B	1000 mm
Depth	D	200 mm
Maximum Bar dia	Db	10 mm
Density of concrete	Wd	25 kN/m ³
Loading		
Live load	LI	1.5 kN/m ²
Finishing load	FI	1 kN/m ²
CALCULATION		
Calculation of loading	DI	5 kN/m ²
Self wt (Dead load)	TI	7.5 kN/m ²
Total Load	De	150 mm
Effective depth		
Bending Moment	Bm	8.438 KN-m
Modular ratio		9.33
K	k	0.42
j = 1-K/3	j	0.9
Ast		502.7 mm ²

Provide : 10 dia - 150 c/c

Root slab design as circular slab

[C] CYLINDRICAL WALL

inner diameter	cyid	6.000	m
top thickness	cytt	0.175	m
bottom thickness	cybt	0.175	m
Water depth	cyh	3.400	m
coefficient of constant height	cyc	0.000	
free board		0.300	m

height of wall for design	cy/h	3.700	m
increment in thickness	cy/h	0.000	m

Hoop Force : Wall free at Top and hinge at bottom condition

$F = coe \times H \times D / 2$

F = Hoop force

H = Height of water above that section
 D = Diameter of wall at that section

Ration H^2/DT 13.038
 Enter Value for Auto serach 12.000

h

hoop force

sr. no	depth from top in meter	thickness at section	coefficient	hoop force in wall = Coe. X rad * height * unit wt of liquid	area of steel required = force / 1300	actual tensile stress in concrete = force/(h*wt*ast)	Minimum Area of steel in mm2 on each face
1	0.370	0.175	0.001	0.1	1	0.001	210
2	0.740	0.175	0.098	10.8	83	0.060	210
3	1.110	0.175	0.197	21.9	168	0.120	210
4	1.480	0.175	0.300	33.3	257	0.184	210
5	1.850	0.175	0.412	45.8	352	0.252	210
6	2.220	0.175	0.536	59.5	457	0.328	210
7	2.590	0.175	0.661	73.4	565	0.404	210
8	2.960	0.175	0.756	83.9	645	0.462	210
9	3.330	0.175	0.737	81.8	629	0.450	210
10	3.700	0.175	0.496	55.0	423	0.303	210
	area of steel requd	dia of bar	bar spacing	area of steel prod			
1	210.000	10	200	785			
2	210.000	10	200	785			
3	210.000	10	200	785			
4	256.532	10	200	785			
5	352.065	10	200	785			
6	457.499	10	200	785			
7	564.738	10	200	785			
8	645.260	10	200	785			
9	628.951	10	200	785			
10	423.239	10	200	785			

FOUNDATION DESIGN

WALL FOOTING DESIGN		PROJECT : P16_02_Adiabad W.S.S		JOB : P16_02	
UNIT : 90KL GLBR		WALL TYPE 1		W1	
BASIC DATA					
Density of water	denwt	10	kN/m ³	fyc	130
Density of soil	denso	18	kN/m ³	fycb	130
Density of concrete	decon	25	kN/m ³	fcck	10.0
Angle of Repose	Phi	30	degree	fckt	1.5
Safe bearing capacity of soil	Sbc	150.0	kN/m ²	modular ratio	9.33
Concrete grade	Fck	30	N/mm ²	K	0.42
Steel grade	Fy	500	N/mm ²	J	0.86
Depth below GI	Dbg	0.50	m		
Water depth	wtd	3.40	m		
free board	fb	0.30	m		
Wall above Ground		2.00	m		
Clear cover	Cv	50	mm		
Maximum size of bar dia	Db	10	mm		
Water depth with free board	Wd	3.70	m		
minimum % steel	pt	0.24	%		
Moment	Mtw	4.85	kN-m		
Due to Water	Mts	0.50	kN-m		
Due to soil if any	Slabwt	11.30	kN-m		
Wall geometry (Figure 1)					
Straight portion	lb	3.700	m		
Tapered portion	lc	0.000	m		
	tb	0.175	m		
	td	0.175	m		
Footing geometry	ht	0.300	m		
Toe projection	hh1	0.450	m		
Heel straight projection	hh2	0.000	m		
Heel tapered projection	hh3	0.450	m		
Heel portion for soil stability	tha	0.200	m		
Thickness at toe (free end)	tta	0.200	m		
Thickness at heel (wall face)	tth	0.200	m		
Thickness at heel (free face)	thb	0.200	m		
Total Height of Wall	THw	3.700	m		
Total length of wall footing	wf	0.925	m		
CASE 1 : TANK FULL CONDITION WITH NO SOIL OUTSIDE					
Total load & Moment calculation @ toe					
Component	Wt	KN	Arm	Moment	
Wall Straight portion	W1	16.19	m	6.27	
Wall Tapered portion	W2	0.00	m	0.00	

Design of Toe - At Point A			
Walkway/slab	P	11.30	0.39
Footing			
Footing : toe	W3	1.50	0.15
Footing center	W4	0.88	0.39
Footing : heel (straight)	W5	2.25	0.70
Footing : heel (tapered)	W6	0.00	0.93
Water	W7	16.65	0.70
Total downward load		48.76	24.45
Total restoring moment @ toe	TRM	24.4	KN-m
Total over turning moment		4.9	KN-m
F.S. against over turning		5.0	
Check for over turning		Hense o.k	
Total moment due to vertical load	Tmv	24.4	KN-m
Total moment due to horizontal load	Tmh	4.9	KN-m
Total vertical load	TPV	48.8	kn
Net Moment	Tmn	19.6	KN-m
M/p	E	0.40	m
Ecc	Ecc	0.061	m
b/6	Aec	0.15	m
Net moment From ECC	Mdg	2.957	
Property of footing			
Width of footing		1.00	m
Depth of footing		0.93	m
Footing Area	Fare	0.93	m2
Modulus of section	Fz	0.14	m3
Pressure distribution			
=P/A	prea	52.72	KN/m2
Pressure due to direct load			
=M/Z	Preb	20.74	KN/m2
Pressure			
Maximum pressure - P/A +	Pmax	73.45	KN/m2
Minimum pressure - P/A +	Pmin	31.98	KN/m2
Check for SBC			
Maximum pressure < SBC		OK	
Minimum pressure > 0		OK	
Pressure difference		41.47	
Pressure difference / m		44.84	
Pressure at outer Wall face -			
A	preow	60.00	KN/m2
Pressure at inner			
Wall face B	prew	52.16	KN/m2
Pressure at point	prew1	31.98	KN/m2
C			




Moment at face of outer wall		Due to rectangle diagram		Mreco	2.70	kN-m
Total moment due to upward pressure		Net moment at A from Toe		Toem	3.10	kN-m
side		Thickness at toe			200	mm
Effective depth		Ast required =		Defoe	145	mm
Check for minimum steel		top			240	mm2
bottom		Design Steel			0	mm2
Main steel - Top		Main steel - bottom			240	mm2
Distribution steel - top		Distribution steel - bottom			240	mm2
Distribution steel - bottom					0	mm2
Design of heel : At point B & C						
Due to rectangle diagram (upward)		Due to rectangle diagram (upward)		Mrecl	3.2	kN-m
Total Upward moment		Due to water (down ward)		Mtril	0.7	kN-m
Due to water (down ward)		Net downward moment at B from heel side		heelm	3.7	kN-m
Thickness Provided		Ast required =		defheel	200	mm
Check for minimum steel - straight portion		top			145	mm
bottom		Design Steel			11	mm2
Main steel - Top		Main steel - bottom			240	mm2
Distribution steel - top		Distribution steel - bottom			240	mm2
Distribution steel - bottom					0	mm2
Design at point B						
Due to rectangle diagram (upward)		Due to rectangle diagram (upward)		Mrecl	0.00	kN-m
Total Upward moment		Due to water (down ward)		Mtril	0.00	kN-m
Due to water (down ward)		Net downward moment at B from heel side		heelm	0.00	kN-m
Thickness Provided		Ast required =		defheel	200	mm
Check for minimum steel - tapered portion		top			145	mm
bottom		Design Steel			0	mm2
Main steel - Top		Main steel - bottom			240	mm2
Distribution steel - top		Distribution steel - bottom			240	mm2
Distribution steel - bottom					0	mm2
Design at point C						
Due to rectangle diagram (upward)		Due to rectangle diagram (upward)		Mrecl	0.00	kN-m
Total Upward moment		Due to water (down ward)		Mtril	0.00	kN-m
Due to water (down ward)		Net downward moment at B from heel side		heelm	0.00	kN-m
Thickness Provided		Ast required =		defheel	200	mm
Check for minimum steel - tapered portion		top			145	mm
bottom		Design Steel			0	mm2
Main steel - Top		Main steel - bottom			240	mm2
Distribution steel - top		Distribution steel - bottom			240	mm2
Distribution steel - bottom					0	mm2

Total load & Moment calculation		Taking moment @ toe		Component	
Wt	Lever Arm	Moment	Wt	Dist	W * dist
W1	16.19	0.54	16.19	0.54	8.70
W2	0.00	0.63	0.00	0.63	0.00
P	11.30	0.54	11.30	0.54	6.07
W3	1.50	0.78	1.50	0.78	1.16
W4	0.88	0.54	0.88	0.54	0.47
W5	2.25	0.23	2.25	0.23	0.51
W6	2.70	0.78	2.70	0.78	2.09
34.81		19.0		19.01	
Total downward load		TRMs		Total restoring moment @ heel	
		19.0		Total over turning moment due to soil	
		0.5		F.S.against over turning	
		38.0		Check for over turning	
		Hense o.k		Total moment due to vertical load	
		19.0		Total moment due to horizontal load	
		0.5		Tmh1	

CASE 2 : TANK EMPTY CONDITION WITH SOIL OUTSIDE

Pressure Check		Reinforcement	
>1	>2	>	<
M/Z	M/Z	OK	OK
P/A +	P/A -	0	150
32	73.5	0	150
SUMMARY			
AstR		Astp	
Top - main	240	10	200
Bottom main	191	10	200
Top - Dist	240	10	200
Bottom - Dist	0	10	200
Heel Straight portion			
Top - main	240	10	200
Bottom main	0	10	200
Top - Dist	240	10	200
Bottom - Dist	0	10	200
Heel tapered portion			
Top - main	240	10	200
Bottom main	0	10	200
Top - Dist	240	10	200
Bottom - Dist	0	10	200
Top - main	240	10	200
Bottom main	0	10	200
Top - Dist	240	10	200
Bottom - Dist	0	10	200

Net vertical load	TPV1	34.8	kn
Net Moment	Tm1	18.5	kn-m
M/p	E1	0.53	m
Ecc	Ecc1	-0.069	m
b/6	Aec1	0.15	m
Net moment From ECC	Mdg1	-2.4053	m
Property of footing			
Width of footing		1.00	m
Depth of footing		0.93	m
Footing Area	Fare1	0.93	m2
Modulus of section	Fz1	0.14	m3
Pressure due to direct load = P/A	prea1	37.64	kn/m2
Pressure due to moment = M/Z	preb1	-16.9	kn/m2
Maximum pressure - P/A + M/Z	Pmax1	20.77	kn/m2
Minimum pressure - P/A + M/Z	Pmin1	54.50	kn/m2
Check for SBC		OK	
Maximum pressure < SBC		OK	
Minimum pressure > 0		OK	
Pressure difference		-33.73	kn/m2
Pressure difference / m		-36.47	kn/m2
Pressure at outer Wall face - A	prew1	43.56	kn/m2
Pressure at inner Wall face B	prei1	37.18	kn/m2
Pressure due to direct load = P/A	prea1	37.64	kn/m2
Pressure due to moment = M/Z	preb1	-16.9	kn/m2
Maximum pressure - P/A + M/Z	Pmax1	20.77	kn/m2
Minimum pressure - P/A + M/Z	Pmin1	54.50	kn/m2
Check for SBC		OK	
Maximum pressure < SBC		OK	
Minimum pressure > 0		OK	
Pressure difference		-33.73	kn/m2
Pressure difference / m		-36.47	kn/m2
Pressure at outer Wall face - A	prew1	43.56	kn/m2
Pressure at inner Wall face B	prei1	37.18	kn/m2
Moment at face of outer wall	Mreo1	2.45	kn-m
Due to rectangular diagram		-0.16	kn-m
Due to triangular diagram	Mtri1	2.29	kn-m
Total downward moment due to soil		0.41	kn-m
Net moment at A from Toe side	Toem1	-1.88	kn-m
Thickness at toe		200	mm
Effective depth		145	mm
As1 required =		#####	mm2
Check for minimum steel		240	mm2
top		240	mm2
bottom		0	mm2
Design Steel		240	mm2
Main steel - Top		240	mm2
Main steel - bottom		0	mm2
Distribution steel - top		240	mm2
Distribution steel - bottom		0	mm2
Design of heel : At point B			
Due to rectangle diagram (upward)	Mrec1	3.76	kn-m
Due to triangular diagram (upward)	Mtri1	-1.11	kn-m
Total Upward moment	heelm1	2.66	kn-m
Net downward moment at B from heel side		200	mm
Thickness Provided		145	mm
Steel required at bottom		164	mm2
As1 required =		240	mm2
Check for minimum steel - straight portion		240	mm2
top		240	mm2
bottom		0	mm2
Design Steel		240	mm2
Main steel - Top		240	mm2
Main steel - bottom		0	mm2
Distribution steel - top		240	mm2
Distribution steel - bottom		0	mm2






“Designs Vetted”



Asst Executive Engineer TDWSP Asifabad
 Dy. Executive Engineer TDWSP Asifabad
 Executive Engineer TDWSP Asifabad

Handwritten signature in green ink.

Total shear = 26.36
 Shear = 8.039 KN
 effective depth = 145 mm
 Shear stress = 0.055 N/mm²



Effective depth = 145 mm
 Pressure at Effective depth = 31.91
 Shear to be checked at effective depth D
 Pressure at outer face of wall = 43.57 kN/m²
 Pressure at inner face of wall = 37.19 kN/m²
 Pressure Difference / m = 36.43 kN/m²
 Difference in pressure = 33.70 kN/m²
 Total Width = 925 mm




SHEAR CHECK FOR SOIL
 Cover 50
 Dia 10

Handwritten signature in green ink.
 Superintendent Engineer TDWSP Nirmal



APPROVED
 SE, TDWSP NIRMAL
Handwritten signature in green ink.





"Drawings Vetted"

Asst Executive Engineer
TDWSP Asifabad

Dy. Executive Engineer
TDWSP Asifabad

Executive Engineer
TDWSP Asifabad



SCHEDULE OF PIPE	
INLET PIPE SIZE	-
OUTLET PIPE SIZE	-
OVER FLOW PIPE SIZE	-

NOTES :
 <1> ALL DIMENSION ARE IN MM AND LEVELS ARE IN METER.
 <2> LOCATION & LEVELS OF INLET,OUTLET & OVERFLOW PIPE SHALL BE VARIED WITH ENGINEER INCHARGE BEFORE EXECUTION

RELEASED FOR <input type="checkbox"/> PRELIMINARY <input type="checkbox"/> TENDER <input type="checkbox"/> INFORMATION <input checked="" type="checkbox"/> APPROVAL <input type="checkbox"/> CONSTRUCTION	DRAWING No. LE150883-0883-C-W-S-R-W-GA-1589 SHEET 1 OF 1 COMP. DATA : P16-02_48-01-01														
JOB No. : LE150883 TITLE : 90KL CAPACITY GBRAT MADHARAM GUTTA (GENERAL ARRANGMENT DRAWING)	<table border="1"> <tr> <td>APPD</td> <td>-</td> <td>04/07/16</td> </tr> <tr> <td>CHKD</td> <td>RMM</td> <td>04/07/16</td> </tr> <tr> <td>DRWN</td> <td>DAP</td> <td>04/07/16</td> </tr> <tr> <td>DSGN</td> <td>HMP</td> <td>04/07/16</td> </tr> </table>	APPD	-	04/07/16	CHKD	RMM	04/07/16	DRWN	DAP	04/07/16	DSGN	HMP	04/07/16		
APPD	-	04/07/16													
CHKD	RMM	04/07/16													
DRWN	DAP	04/07/16													
DSGN	HMP	04/07/16													
SCALE 1:50 PROJECTION	SUPPLIER / CONTRACTOR : L&T Construction Water & Effluent Treatment SBG PROJECT : PROVIDING DRINKING WATER TO HABITATIONS IN KOMARAMBHEEM ASIFABAD SEGMENT IN ADILABAD DISTRICT CLIENT : RURAL WATER SUPPLY AND SANITATION DEPARTMENT, TELANGANA CONSULTANT : L&T Construction Water, Smart World & Communication.														
REVISIONS	<table border="1"> <thead> <tr> <th>REV. No</th> <th>DESCRIPTION</th> <th>DATE</th> <th>DESIGNED</th> <th>DRAWN</th> <th>CHECKED</th> <th>APPROVED</th> </tr> </thead> <tbody> <tr> <td>A</td> <td>FOR APPROVAL</td> <td>04/07/16</td> <td>-</td> <td>DAP</td> <td>RMM</td> <td>-</td> </tr> </tbody> </table>	REV. No	DESCRIPTION	DATE	DESIGNED	DRAWN	CHECKED	APPROVED	A	FOR APPROVAL	04/07/16	-	DAP	RMM	-
REV. No	DESCRIPTION	DATE	DESIGNED	DRAWN	CHECKED	APPROVED									
A	FOR APPROVAL	04/07/16	-	DAP	RMM	-									








Superintendent Engineer
TDWSP Nirmal



SE, TDWSP
NIRMAL

"APPROVED"

SIZE REV. A3 A



LAP LENGTH SCHEDULE

DIA OF BAR	LAP LENGTH "L" IN MM
8	368
10	460
12	552
16	736
20	920
25	1150

- NOTES:
- 1 ALL DIMENSIONS ARE IN MM AND LEVELS ARE IN METER.
 - 2 ALL CONCRETE MIX M-30 WITH MAXIMUM FREE WATER CEMENT RATIO OF 0.45.
 - 3 ALL CONCRETE SHALL BE MACHINE MIXED AND MACHINE VIBRATED.
 - 4 # - INDICATE HYSD-TMT BAR FT-500 GRADE 1 CONFORMING TO IS 1786-LATEST REVISION.
 - 5 CLEAR COVER TO WATER RETAINING STRUCTURE.
 - 6 (A) BOTTOM SLAB : 50mm
 - 6 (B) WALL WATER FACE : 45mm & SOIL FACE : 20mm
 - 6 (C) TOP SLAB : 45mm
 - 7 FOUNDATION SHALL REST ON IN-SITU SOIL AND IT SHALL NOT BE ON FILLING MATERIAL. MAKE UP SOIL OR HIGHLY COMPRESSIBLE SOIL.
 - 8 BAK FILLING SHALL BE DONE IN WELL COMPACTED AND WELL WATER LAYER NOT EXCEEDING 150mm IN DEPTH.
 - 9 SFC CONSIDERED IN DESIGN IS 15 T/M² & NO GROUND WATER TABLE.
 - 10 INLET & OVERFLOW PIPE SHALL BE DECIDED AS PER SITE CONDITION.
 - 11 LOCATION & LEVELS OF INLET/OUTLET & OVERFLOW PIPE SHALL BE VERY WITH ENGINEER'S NOVICE BEFORE EXECUTION.

RELEASED FOR: PRELIMINARY TENDER INFORMATION APPROVAL CONSTRUCTION

COMP. DATA: P18-02-46-02-01

DRAWING No. [Grid] SHEET 1 OF 1

JOB No. LE150883

TITLE: Water & Effluent Treatment SWS

PROJECT: PROVIDING DRINKING WATER TO HABITATIONS IN KOMARABHARHEM ASIFAAD SEGMENT IN ADILABAD DISTRICT

CLIENT: RURAL WATER SUPPLY AND SANITATION

CONSULTANT: L&T Construction

REVISIONS:

REV. NO.	DESCRIPTION	DATE	DESIGNED	CHECKED	APPROVED
A	FOR APPROVAL	21/07/16	RPS	DAP	RMM



Superintendent Engineer
 TDWSP Nirmal



APPROVED
 SE, TDWSP
 NIRMAL

Asst Executive Engineer Dy. Executive Engineer TDWSP Asifabad

Executive Engineer TDWSP Asifabad