


- NOTES**
1. CONCRETE (ALL MEMBERS) : M30
 2. STEEL : Tor 40, Fe 415
 3. CLEAR MINIMUM COVER
SIDE WALLS : 45MM
TOP & BOTTOM SLABS : 45MM
 4. SBC : 10T/SQM
 5. ALL DIMENSION AR IN MM UNLESS SPECIFIED.
 6. THE STEEL SHOULD NOT BE OVERLAPPED AT THE JUNCTION POINTS.
 7. NOT MORE THAN 1/3rd OF THE BARS SHOULD BE CURTAILED AT A GIVEN SECTION.
 8. AS PER IS 3370, THE MAXIMUM SPACING OF REINFORCEMENT SHOULD NOT EXCEED 300MM OR THICKNESS OF SECTION WHICH EVER IS LESS

PROJECT :	PROVIDING DRINKING WATER IN SEGMENT 13 (SINGOOR-JUKKAL) OF NIZAMABAD DISTRICT.		
CLIENT :	GOVERNMENT OF TELANGANA RURAL WATER SUPPLY & SANITATION DEPARTMENT, NIZAMABAD (DIST.)		
CONSULTANT :	 M/S MEGHA ENGINEERING & INFRASTRUCTURES LIMITED S-2 TECHNOCRAT INDUSTRIAL ESTATE, BALANAGAR HYDERABAD-500 037		
JOB No.:	TITLE:		SCALE
DSGN	NAME	SIGN	DATE
DRWN	RRB		07.01.16
CHKD	KSK		07.01.16
	ISK		07.01.16
DRAWING No. TWG/NS-13/TADGUR SMALL/SUMP/01		SHEET: A0	01 OF 01
RELEASED FOR		REVISION: 0	PROJECTION
<input type="checkbox"/> PRELIMINARY	<input type="checkbox"/> TENDER	<input type="checkbox"/> INFORMATION	<input checked="" type="checkbox"/> APPROVAL
<input type="checkbox"/> CONSTRUCTION			